

Test sponsor	Certificate number	Certificate issue date	Certificate expiry date
Roof TG Pacific Limited 17 Avatonbell Drive Luscombe, QLD 4207 Australia	26999 SFC5.0	31 July 2020	31 July 2025

### Description of assessed system

The assessment is to determine the likely performance of the Gerard roofing tiles installed in a roofing system if tested in accordance with AS 1530.8.2:2007 with BAL FZ exposure. It is to be noted that although a new version of the standard, namely AS 1530.8.2:2018, has already been released, tests conducted previously in accordance with AS 1530.8.2:2007 remain valid (refer to AS 1530.8.2:2018 and AS 3959:2018).

### Assessed system and product performance

The element of construction described above was assessed by this laboratory on behalf of the test sponsor in accordance with the stated test standard in Table 1 and achieved the results outlined in Table 2. Complete description of the assessed construction can be found within the referenced assessment report.

**Table 1 Test standard and assessment report details**


Referenced report	Test standard	Referenced report issue date	Referenced report expiry date
26999 R5.0	AS 1520.8.2:2007	31 July 2020	31 July 2025

**Table 2 Formal assessment summary**

Roof system description	Performance in accordance with AS1530.8.2:2007
Gerard Roof tiles with the following: <ul style="list-style-type: none"> <li>Heritage, Stratos, Rockport and Milano in satin or textured finishes.</li> <li>Gerard Roof tile is of nominally 0.5 mm with satin finish and 1.5 mm with textured finish.</li> </ul> The roof tiles shall be installed in conjunction with the TBA Firefly BAL-FZ roofing system.	BAL-FZ

### Conditions/validity

- This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.
- The RIR (regulatory information report) or the main assessment report must be provided for regulatory requirements and evidence of compliance.
- Reference should be made to the relevant assessment report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The results of the assessment report may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.
- All work and services carried out by Warringtonfire Australia are subject to and conducted in accordance with our standard terms and conditions. These are available on request or at <https://www.element.com/terms/terms-and-conditions>.

<b>Testing authority</b>	Warringtonfire Australia Pty Ltd	
<b>Address</b>	Unit 2, 409-411 Hammond Road, Dandenong South, VIC 3175	
<b>Phone</b>	T: +61 (0)3 9767 1000	
<b>ABN</b>	81 050 241 524	
<b>Email</b>	info.fire.melbourne@warringtonfire.com	
<b>Authorisation</b>	Prepared by:	Reviewed by:
		
	Hon Wong	Imran Ahamed